

# ANSI/IES LM-79-19

## MEASUREMENT AND TEST REPORT

For

### GREEN CREATIVE LTD

Room 3603, Level 36, Tower 1, Enterprise Square Five, 38 Wang Chiu Road, Kowloon Bay, Kowloon,  
Hong Kong, China

**Test Model: 11PAR30DIM/950FL40/SL**

<b>Report Type:</b>	Electrical and Photometric tests including: Luminous Flux, Chromaticity, Luminous Intensity Distribution, THD
<b>Reviewed By:</b>	Hill Liu <span style="float: right;">Hill Liu</span>
<b>Report Number:</b>	KS2230727-43628E-EE
<b>Test Date:</b>	2023-07-26 to 2023-07-27
<b>Report Date:</b>	2023-08-25
<b>Approved by:</b>	Blake Zhang / EE Engineer
<b>Prepared By:</b>	Bay Area Compliance Laboratories Corp. (Shenzhen) 5/F(B-West) -7/F, the 3rd Phase of Wan Li Industrial Building D, Shihua Road, Futian Free Trade Zone Shenzhen, Guangdong, China. Tel: +86-755-33320018 Fax: +86-755-33320008
<b>Test Facility:</b>	Test facility was located at No.12, Pulong East 1 <sup>st</sup> Road, Tangxia Town, Dongguan, Guangdong, China.

**Note:** This test report is prepared for the customer shown above and for the device described herein. It may not be duplicated or used in part without prior written consent from Bay Area Compliance Laboratories Corp.(Shenzhen). This report must not be used by the customer to claim product certification, approval, or endorsement by NVLAP, or any agency of the U.S. Government.

## 1. Product Description#

### General Information:

Two test samples were in good condition and received on 2023-07-27. One was tested in integrating sphere and the other was tested in goniophotometer

Model Tested: 11PAR30DIM/950FL40/SL  
Manufacturer: GREEN CREATIVE LTD  
Brand Name: GREEN CREATIVE  
Product Designation: Directional LED Lamp  
Burning Time Before Test: 0hour(For New Products)

### Rated Values:

Rated Voltage/Frequency: 120V AC 60Hz  
Rated Power: 11W  
Nominal CCT: 5000K  
Nominal Lumen Output: 1030lm

## 2. Standards Used

- ANSI/IES LM-79-19: Approved method: Optical and Electrical Measurements of Solid-State Lighting Products
- ANSI C82.77-10-2014: Harmonic Emission Limits – Related Power Quality Requirements for Lighting
- \*IES TM-30-18: IES Method for Evaluating Light Source Color Rendition (This method is not in NVLAP accreditation scope)

### 3. Description of Test Equipment

Device	Manufacture	Model No	Serial No	Calibration date	Calibration due date
2.0m integrating sphere	EVERFINE	R98	11010018	2022-11-10	2023-11-09
spectroradiometer	EVERFINE	HAAS-2000	G112048TS81331121	2022-11-10	2023-11-09
Digital Power Meter	EVERFINE	PF2010A	1011004	2022-11-10	2023-11-09
Digital CC&CV DC Power Supply	EVERFINE	WY305-V1	1101047	2022-11-10	2023-11-09
Standard Light Source	EVERFINE	D204	N/A	2023-05-12	2025-05-11
Special zero-voltage synchronous switching AC	EVERFINE	DPS1010-YF	1011001T	2022-11-10	2023-11-09
AC POWER SUPPLY	EVERFINE	VPS1030 PWM	1012017	2022-11-16	2023-11-15
Digital CC&CV DC Power Supply	EVERFINE	WY12010	1009009	2022-11-10	2023-11-09
Digital power meter	YOKOGAWA	WT-210	91j926132	2022-11-10	2023-11-09
full-field speed goniophotometer	EVERFINE	GO-R5000	YG108492N10120001	2022-11-10	2023-11-09
wireless remote thermohygrometer	N/A	AOK-5017B	N/A	2022-11-10	2023-11-09
Standard Light Source	EVERFINE	D908	1012003	2023-05-12	2025-05-11

Statement of Traceability: Bay Area Compliance Laboratories Corp. (Shenzhen) attested that all calibration has been performed using suitable standards traceable to National Primary Standards and International System of Units (SI).

## 4. Test Method

Product was tested with no seasoning. All stabilization and measurements were made in compliance with ANSI/IES LM-79-19. The product was operated at rated voltage or at voltage required by manufacturer. The ambient temperature of the sample was maintained at  $25^{\circ}\text{C} \pm 1.2^{\circ}\text{C}$  during measurement. And relative humidity is maintained between 10% and 65%. The air flow around the SSL product is less than 0.2m/s.

### Integrating Sphere System

The system includes AC power source, digital power meter, DC power supply, Spectroradiometer, and integrating sphere. The integrating sphere system is calibrated by standard spectrum light source before measurement.

$4\pi$  geometry was used during measurement. The product was operated in its intended orientation in application and was recorded in this report.

The uncertainty of the light output (luminous flux) measurements is  $U=2.1\%$  ( $K=2$ ), at the 95% confidence level. The uncertainty of the correlated color temperature measurements is  $U=22\text{K}$  ( $K=2$ ), at the 95% confidence level. The uncertainty of the CRI is  $U=2.1(K=2)$ , at the 95% confidence level.

The uncertainty of power meter AC current  $U=0.19\%$  of rdg, AC Voltage  $U=0.18\%$  of rdg, Power  $U=0.46\%$  ( $K=2$ ), at the 95% confidence level.

### Goniophotometer System

The goniophotometer system is calibrated by standard light source before measurement.

Type C goniophotometer was used for measuring total luminous flux, luminous intensity distribution, and color spatial uniformity. The product was operated in its intended orientation in application and was recorded in this report. The vertical angle ( $\gamma$ ) test intervals were set no more than 1 degree while data for 5 degree intervals is reported. The horizontal angle (C plane) test intervals were set no more than 22.5 degree.

The uncertainty of the luminous intensity is  $U=2.00\%$  ( $K=2$ ), at the 95% confidence level.

### Additional Test

The Additional Test item may not be covered by ANSI/IES LM-79-2019. Additional test including power factor, off-state power and THD, was measured by Digital Power Meter after stabilized at  $25^{\circ}\text{C} \pm 1.2^{\circ}\text{C}$ . Test voltage for THD and power factor test would be equal to rated voltage or, in case of a voltage range, maximum value of that range.

The uncertainty of power meter AC current  $U=0.19\%$  of rdg, AC Voltage  $U=0.18\%$  of rdg, Power  $U=0.46\%$  ( $K=2$ ), at the 95% confidence level.

### Fidelity Index and Gamut Index Calculation

The  $R_i$ ,  $R_g$  was calculated according to IES TM-30-18 by using calculation tools. The calculation was based on the measured SPD from 380nm to 780nm with 1nm intervals. All the colors in this report is for reference only.

## 5. Test Result

### [Integrating Sphere System]

The Stabilization time: **30 minutes**

Total operating time for integrating sphere test: **1.0 hour**

Test orientation: **Base Up**


### Photometric and Electrical Measurement Result




Voltage (V)	Frequency (Hz)	Current (A)	Power (W)	Power Factor	Luminous Flux(lm)	Efficacy (lm/W)
120.0	60	0.09127	10.42	0.951	1033.8	99.22

Radiant Flux (W)	CCT (K)	Duv	x	y	u'	v'
3.851	4911	0.000607	0.3478	0.3550	0.2119	0.4867


### Color Rendering Index

<b>Ra</b>			
<b>96.5</b>			
<b>R1</b>	<b>R2</b>	<b>R3</b>	<b>R4</b>
96	98	98	97
<b>R5</b>	<b>R6</b>	<b>R7</b>	<b>R8</b>
96	97	96	94
<b>R9</b>	<b>R10</b>	<b>R11</b>	<b>R12</b>
88	98	99	74
<b>R13</b>	<b>R14</b>	<b>R15</b>	
96	98	93	





### Relative Spectral Power Distribution




nm	mW	nm	mW	nm	mW	nm	mW	nm	mW
380	5.226E-01	421	1.059E+00	462	1.675E+01	503	1.284E+01	544	1.488E+01
381	4.696E-01	422	1.161E+00	463	1.629E+01	504	1.297E+01	545	1.487E+01
382	4.640E-01	423	1.281E+00	464	1.591E+01	505	1.307E+01	546	1.484E+01
383	4.223E-01	424	1.430E+00	465	1.552E+01	506	1.314E+01	547	1.483E+01
384	3.686E-01	425	1.567E+00	466	1.526E+01	507	1.328E+01	548	1.479E+01
385	3.638E-01	426	1.765E+00	467	1.489E+01	508	1.335E+01	549	1.476E+01
386	3.293E-01	427	1.961E+00	468	1.447E+01	509	1.343E+01	550	1.477E+01
387	3.026E-01	428	2.158E+00	469	1.405E+01	510	1.352E+01	551	1.470E+01
388	2.875E-01	429	2.400E+00	470	1.354E+01	511	1.360E+01	552	1.467E+01
389	2.558E-01	430	2.661E+00	471	1.306E+01	512	1.370E+01	553	1.462E+01
390	2.421E-01	431	2.958E+00	472	1.257E+01	513	1.377E+01	554	1.458E+01
391	2.252E-01	432	3.275E+00	473	1.210E+01	514	1.389E+01	555	1.452E+01
392	1.944E-01	433	3.635E+00	474	1.169E+01	515	1.393E+01	556	1.448E+01
393	2.343E-01	434	4.015E+00	475	1.135E+01	516	1.400E+01	557	1.441E+01
394	2.009E-01	435	4.459E+00	476	1.110E+01	517	1.404E+01	558	1.440E+01
395	2.057E-01	436	4.957E+00	477	1.092E+01	518	1.414E+01	559	1.431E+01
396	1.848E-01	437	5.489E+00	478	1.078E+01	519	1.418E+01	560	1.427E+01
397	1.973E-01	438	6.126E+00	479	1.073E+01	520	1.428E+01	561	1.420E+01
398	1.956E-01	439	6.799E+00	480	1.071E+01	521	1.434E+01	562	1.415E+01
399	2.094E-01	440	7.594E+00	481	1.075E+01	522	1.439E+01	563	1.412E+01
400	2.054E-01	441	8.523E+00	482	1.082E+01	523	1.445E+01	564	1.407E+01
401	2.163E-01	442	9.538E+00	483	1.085E+01	524	1.450E+01	565	1.404E+01
402	2.242E-01	443	1.076E+01	484	1.091E+01	525	1.455E+01	566	1.395E+01
403	2.258E-01	444	1.210E+01	485	1.097E+01	526	1.461E+01	567	1.391E+01
404	2.300E-01	445	1.362E+01	486	1.102E+01	527	1.465E+01	568	1.386E+01
405	2.436E-01	446	1.527E+01	487	1.111E+01	528	1.468E+01	569	1.382E+01
406	2.608E-01	447	1.706E+01	488	1.116E+01	529	1.472E+01	570	1.377E+01
407	2.766E-01	448	1.883E+01	489	1.123E+01	530	1.477E+01	571	1.372E+01
408	2.895E-01	449	2.059E+01	490	1.130E+01	531	1.479E+01	572	1.366E+01
409	3.103E-01	450	2.208E+01	491	1.137E+01	532	1.482E+01	573	1.364E+01
410	3.454E-01	451	2.332E+01	492	1.151E+01	533	1.484E+01	574	1.359E+01
411	3.802E-01	452	2.412E+01	493	1.158E+01	534	1.486E+01	575	1.356E+01
412	4.128E-01	453	2.449E+01	494	1.174E+01	535	1.490E+01	576	1.355E+01
413	4.602E-01	454	2.426E+01	495	1.184E+01	536	1.491E+01	577	1.351E+01
414	4.975E-01	455	2.362E+01	496	1.200E+01	537	1.489E+01	578	1.349E+01
415	5.644E-01	456	2.268E+01	497	1.210E+01	538	1.494E+01	579	1.348E+01
416	6.288E-01	457	2.152E+01	498	1.221E+01	539	1.495E+01	580	1.347E+01
417	6.861E-01	458	2.029E+01	499	1.237E+01	540	1.494E+01	581	1.344E+01
418	7.750E-01	459	1.919E+01	500	1.251E+01	541	1.492E+01	582	1.344E+01
419	8.671E-01	460	1.818E+01	501	1.260E+01	542	1.495E+01	583	1.340E+01
420	9.519E-01	461	1.738E+01	502	1.274E+01	543	1.490E+01	584	1.343E+01


nm	mW	nm	mW	nm	mW	nm	mW	nm	mW
585	1.342E+01	626	1.583E+01	667	1.204E+01	708	5.148E+00	749	1.654E+00
586	1.343E+01	627	1.585E+01	668	1.189E+01	709	5.023E+00	750	1.606E+00
587	1.346E+01	628	1.588E+01	669	1.171E+01	710	4.867E+00	751	1.569E+00
588	1.346E+01	629	1.589E+01	670	1.152E+01	711	4.771E+00	752	1.519E+00
589	1.352E+01	630	1.590E+01	671	1.135E+01	712	4.628E+00	753	1.487E+00
590	1.355E+01	631	1.586E+01	672	1.116E+01	713	4.528E+00	754	1.439E+00
591	1.359E+01	632	1.587E+01	673	1.096E+01	714	4.444E+00	755	1.394E+00
592	1.361E+01	633	1.586E+01	674	1.078E+01	715	4.318E+00	756	1.370E+00
593	1.366E+01	634	1.585E+01	675	1.059E+01	716	4.190E+00	757	1.331E+00
594	1.371E+01	635	1.583E+01	676	1.042E+01	717	4.085E+00	758	1.287E+00
595	1.377E+01	636	1.577E+01	677	1.020E+01	718	3.993E+00	759	1.260E+00
596	1.384E+01	637	1.573E+01	678	1.002E+01	719	3.881E+00	760	1.226E+00
597	1.390E+01	638	1.570E+01	679	9.846E+00	720	3.763E+00	761	1.193E+00
598	1.396E+01	639	1.565E+01	680	9.651E+00	721	3.665E+00	762	1.153E+00
599	1.402E+01	640	1.560E+01	681	9.501E+00	722	3.571E+00	763	1.115E+00
600	1.411E+01	641	1.553E+01	682	9.316E+00	723	3.477E+00	764	1.098E+00
601	1.417E+01	642	1.543E+01	683	9.138E+00	724	3.402E+00	765	1.062E+00
602	1.424E+01	643	1.539E+01	684	8.957E+00	725	3.288E+00	766	1.020E+00
603	1.432E+01	644	1.529E+01	685	8.761E+00	726	3.220E+00	767	1.006E+00
604	1.440E+01	645	1.517E+01	686	8.585E+00	727	3.121E+00	768	9.766E-01
605	1.446E+01	646	1.510E+01	687	8.414E+00	728	3.036E+00	769	9.392E-01
606	1.455E+01	647	1.499E+01	688	8.248E+00	729	2.945E+00	770	9.236E-01
607	1.463E+01	648	1.490E+01	689	8.066E+00	730	2.866E+00	771	8.858E-01
608	1.475E+01	649	1.476E+01	690	7.898E+00	731	2.780E+00	772	8.698E-01
609	1.480E+01	650	1.467E+01	691	7.714E+00	732	2.702E+00	773	8.395E-01
610	1.488E+01	651	1.453E+01	692	7.552E+00	733	2.631E+00	774	8.141E-01
611	1.496E+01	652	1.440E+01	693	7.395E+00	734	2.561E+00	775	7.980E-01
612	1.507E+01	653	1.427E+01	694	7.229E+00	735	2.483E+00	776	7.709E-01
613	1.512E+01	654	1.417E+01	695	7.076E+00	736	2.403E+00	777	7.443E-01
614	1.520E+01	655	1.401E+01	696	6.887E+00	737	2.341E+00	778	7.370E-01
615	1.525E+01	656	1.386E+01	697	6.733E+00	738	2.278E+00	779	7.384E-01
616	1.534E+01	657	1.371E+01	698	6.578E+00	739	2.215E+00	780	7.398E-01
617	1.540E+01	658	1.354E+01	699	6.438E+00	740	2.150E+00		
618	1.548E+01	659	1.341E+01	700	6.277E+00	741	2.086E+00		
619	1.552E+01	660	1.325E+01	701	6.120E+00	742	2.022E+00		
620	1.560E+01	661	1.309E+01	702	5.984E+00	743	1.964E+00		
621	1.565E+01	662	1.290E+01	703	5.813E+00	744	1.921E+00		
622	1.569E+01	663	1.275E+01	704	5.717E+00	745	1.856E+00		
623	1.574E+01	664	1.259E+01	705	5.543E+00	746	1.806E+00		
624	1.579E+01	665	1.240E+01	706	5.421E+00	747	1.760E+00		
625	1.578E+01	666	1.224E+01	707	5.284E+00	748	1.715E+00		



CIE 1931 x y Chromaticity Diagram



7-Step Chromaticity Quadrangles



**[Goniophotometer System]**

The Stabilization time: **30 minutes**

Total operating time for luminous intensity distribution: **1.0 hour**

Test orientation: **Base up**


**Electrical Measurement**

Input Voltage (V)	Frequency (Hz)	Input Current (A)	Power (W)	Power Factor
120.04	60	0.0916	10.430	0.9486

**Photometric Measurement**

Luminous Flux (lm)	Efficacy (lm/W)	I <sub>max</sub> (cd)	S/MH (C0/180)	S/MH (C90/270)
1035.92	99.32	2103	0.6	0.57

**Luminous Intensity Distribution**



	C0/180	C45/225	C90/270	C135/315	AVG.
Beam Angle (50% I <sub>max</sub> ):	34.5	34.7	34.6	34.5	34.6
Field Angle (10% I <sub>max</sub> ):	67.5	67.1	67.3	67.3	67.3

**Luminous Intensity (cd) Distribution Data**

C y	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°
0.0°	2096	2096	2096	2096	2096	2096	2096	2096
5.0°	1954	1951	1944	1938	1952	1978	1998	1998
10.0°	1590	1588	1597	1612	1634	1684	1723	1746
15.0°	1165	1178	1190	1207	1232	1277	1324	1339
20.0°	778	790	801	809	828	870	900	912
25.0°	482	486	494	497	515	551	570	582
30.0°	285	282	285	289	302	320	338	347
35.0°	170	165	165	168	175	186	196	202
40.0°	105	104	103	105	108	114	120	123
45.0°	73	72	71	73	75	77	80	82
50.0°	57	56	56	57	58	59	60	61
55.0°	46	46	46	46	48	48	49	49
60.0°	36	36	36	36	37	38	39	39
65.0°	26	27	27	27	27	28	29	29
70.0°	19	20	20	20	20	21	21	21
75.0°	13	13	14	14	14	15	15	15
80.0°	8	8	9	9	9	10	10	10
85.0°	4	4	4	4	4	5	5	5
90.0°	1	1	1	1	1	1	2	2
95.0°	0	0	0	0	0	0	0	0
100.0°	0	0	0	0	0	0	0	0
105.0°	0	0	0	0	0	0	0	0
110.0°	0	0	0	0	0	0	0	0
115.0°	0	0	0	0	0	0	0	0
120.0°	0	0	0	0	0	0	0	0
125.0°	0	0	0	0	0	0	0	0
130.0°	0	0	0	0	0	0	0	0
135.0°	0	0	0	0	0	0	0	0
140.0°	1	1	1	1	1	1	1	1
145.0°	1	1	1	1	1	1	1	1
150.0°	2	2	2	2	2	2	2	2
155.0°	2	2	2	2	2	2	2	2
160.0°	2	2	2	2	2	2	2	2
165.0°	2	2	2	2	2	2	2	2
170.0°	2	2	2	2	2	2	2	2
175.0°	2	2	2	2	2	2	2	2
180.0°	1	1	1	1	1	1	1	1

**Luminous Intensity (cd) Distribution Data (cont.)**

C Y	180°	202.5°	225°	247.5°	270°	292.5°	315°	337.5°
0.0°	2096	2096	2096	2096	2096	2096	2096	2096
5.0°	1995	1993	1989	1985	1988	1967	1956	1935
10.0°	1740	1751	1744	1729	1702	1640	1599	1581
15.0°	1323	1317	1305	1287	1257	1202	1162	1152
20.0°	907	903	887	865	846	801	769	767
25.0°	576	576	560	541	529	499	480	476
30.0°	346	346	336	326	318	301	287	284
35.0°	203	203	197	193	189	179	170	170
40.0°	125	124	120	117	114	109	105	105
45.0°	83	82	80	79	77	74	72	72
50.0°	61	61	60	59	59	58	56	57
55.0°	50	50	49	49	48	48	46	46
60.0°	39	39	39	38	38	37	36	35
65.0°	29	29	29	28	28	28	27	26
70.0°	21	22	21	21	21	20	20	19
75.0°	15	15	15	15	15	14	14	13
80.0°	10	10	9	9	9	9	8	8
85.0°	5	5	5	5	4	4	4	4
90.0°	2	2	2	1	1	1	1	1
95.0°	0	0	0	0	0	0	0	0
100.0°	0	0	0	0	0	0	0	0
105.0°	0	0	0	0	0	0	0	0
110.0°	0	0	0	0	0	0	0	0
115.0°	0	0	0	0	0	0	0	0
120.0°	0	0	0	0	0	0	0	0
125.0°	0	0	0	0	0	0	0	0
130.0°	0	0	0	0	0	0	0	0
135.0°	0	0	0	0	0	0	0	0
140.0°	0	0	0	0	0	0	0	0
145.0°	0	0	0	0	0	0	0	0
150.0°	0	0	0	0	1	1	1	1
155.0°	1	1	1	1	1	1	1	1
160.0°	1	1	1	1	1	1	1	1
165.0°	1	1	1	1	1	1	1	1
170.0°	1	1	1	1	1	1	1	1
175.0°	1	1	1	1	1	1	1	1
180.0°	1	1	1	1	1	1	1	1

### Zonal Lumen Density Measurement

Deg	Flux (lm)	%
0-5	48.5	4.68
5-10	130.2	12.57
10-15	171.3	16.54
15-20	169.4	16.34
20-25	140.2	13.54
25-30	103.3	9.97
30-35	70.8	6.83
35-40	48.1	4.65
40-45	34.1	3.29
45-50	26.9	2.59
50-55	22.9	2.21
55-60	19.7	1.91
60-65	15.7	1.52
65-70	12.1	1.17
70-75	9.0	0.87
75-80	6.2	0.59
80-85	3.6	0.35
85-90	1.5	0.15
90-95	0.3	0.03
95-100	0.0	0.00
100-105	0.0	0.00
105-110	0.0	0.00
110-115	0.0	0.00
115-120	0.0	0.00
120-125	0.0	0.00
125-130	0.0	0.01
130-135	0.1	0.01
135-140	0.1	0.01
140-145	0.2	0.02
145-150	0.3	0.03
150-155	0.3	0.03
155-160	0.3	0.03
160-165	0.3	0.03
165-170	0.2	0.02
170-175	0.1	0.01
175-180	0.0	0.00

Deg	Flux (lm)	%
0-5	48.5	4.68
0-10	178.7	17.25
0-15	350.0	33.79
0-20	519.4	50.13
0-25	659.5	63.67
0-30	762.8	73.64
0-35	833.6	80.47
0-40	881.7	85.12
0-45	915.8	88.41
0-50	942.7	91.00
0-55	965.6	93.21
0-60	985.3	95.12
0-65	1001.1	96.64
0-70	1013.2	97.81
0-75	1022.2	98.68
0-80	1028.4	99.27
0-85	1032.0	99.62
0-90	1033.5	99.77
0-95	1033.8	99.80
0-100	1033.8	99.80
0-105	1033.8	99.80
0-110	1033.8	99.80
0-115	1033.8	99.80
0-120	1033.9	99.80
0-125	1033.9	99.80
0-130	1033.9	99.81
0-135	1034.0	99.82
0-140	1034.2	99.83
0-145	1034.4	99.85
0-150	1034.7	99.88
0-155	1035.0	99.91
0-160	1035.3	99.94
0-165	1035.6	99.97
0-170	1035.8	99.99
0-175	1035.9	100.00
0-180	1035.9	100.00

**[Additional Test]**

Test Item	Test Voltage (V)	Frequency (Hz)	Test Result
Total Harmonic Distortion:	120.0	60	16.92%

**6. Product Photo**



## Directions

1. The information marked "superscript #" is provided by the applicant, the laboratory is not responsible for its authenticity and this information can affect the validity of the result in the test report.
2. This report includes some test methods are not in NVLAP accreditation scope marked \*.
3. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.
4. Otherwise required by the applicant or Product Regulations, Decision Rule in this report did not consider the uncertainty.
5. The extended uncertainty given in this report is obtained by combining the standard uncertainty times the coverage factor  $K=2$  with the 95% confidence interval.
6. This report cannot be reproduced except in full, without prior written approval of the Company.
7. This report is valid only with a valid digital signature. The digital signature may be available only under the Adobe software above version 7.0.

\*\*\*\*\*END OF REPORT\*\*\*\*\*