

# IES LM-79-08

## MEASUREMENT AND TEST REPORT

For

### GREEN CREATIVE LTD

Room 3603, Level 36, Tower 1, Enterprise Square Five, 38 Wang Chiu Road, Kowloon Bay, KL, Hong Kong, China

**Test Model:**  
**15.5PAR38/940FL40/277V/SL+SL15D**

<b>Report Type:</b>	Electrical and Photometric tests including: Luminous Flux, Chromaticity, Luminous Intensity Distribution, THD
<b>Reviewed By:</b>	Hill Liu <span style="float: right;">Hill Liu</span>
<b>Report Number:</b>	KS2230727-43691E-EE-1
<b>Test Date:</b>	2023-08-05 to 2023-08-08
<b>Report Date:</b>	2023-08-25
<b>Approved by:</b>	Blake Zhang / EE Engineer
<b>Prepared By:</b>	Bay Area Compliance Laboratories Corp. (Shenzhen) 5/F(B-West) -7/F, the 3rd Phase of Wan Li Industrial Building D, Shihua Road, Futian Free Trade Zone Shenzhen, Guangdong, China. Tel: +86-755-33320018 Fax: +86-755-33320008
<b>Test Facility:</b>	Test facility was located at No.12, Pulong East 1 <sup>st</sup> Road, Tangxia Town, Dongguan, Guangdong, China.

**Note:** This test report is prepared for the customer shown above and for the device described herein. It may not be duplicated or used in part without prior written consent from Bay Area Compliance Laboratories Corp.(Shenzhen). This report must not be used by the customer to claim product certification, approval, or endorsement by NVLAP, or any agency of the U.S. Government.

## 1. Product Description#

### General Information:

Two test samples were in good condition and received on date, and used for testing. One was tested in integrating sphere and the other was tested in goniophotometer

Model Tested: 15.5PAR38/940FL40/277V/SL+SL15D  
Manufacturer: GREEN CREATIVE LTD  
Brand Name: GREEN CREATIVE  
Product Designation: Directional LED Lamp  
Burning Time Before Test: 0hour(For New Products)

### Rated Values:

Rated Voltage/Frequency: AC 120-277V 60Hz  
Rated Power: 15.5W  
Nominal CCT: 4000K  
Nominal Lumen Output: 1420lm

### Family Declaration

The Model	Multiple Models	Differences Items	Details
15.5PAR38/940FL40/277V/SL+SL15D	15.5PAR38/940SP15/277V/SL	Model Number	15.5PAR38/940FL40/277V/SL+SL15D & 15.5PAR38/940SP15/277V/SL are the same product except for the model number.

## 2. Standards Used

- IES LM-79-08: Approved Method: Electrical & Photometric Measurement of Solid-state Lighting Products
- ANSI C82.77-10-2014: Harmonic Emission Limits – Related Power Quality Requirements for Lighting
- \*IES TM-30-18: IES Method for Evaluating Light Source Color Rendition (This method is not in NVLAP accreditation scope)

## 3. Description of Test Equipment

Device	Manufacture	Model No	Serial No	Calibration date	Calibration due date
2.0m integrating sphere	EVERFINE	R98	11010018	2022-11-10	2023-11-09
spectroradiometer	EVERFINE	HAAS-2000	G112048TS81331121	2022-11-10	2023-11-09
Digital Power Meter	EVERFINE	PF2010A	1011004	2022-11-10	2023-11-09
Digital CC&CV DC Power Supply	EVERFINE	WY305-V1	1101047	2022-11-10	2023-11-09
Standard Light Source	EVERFINE	D204	N/A	2023-05-12	2025-05-11
Special zero-voltage synchronous switching AC	EVERFINE	DPS1010-YF	1011001T	2022-11-10	2023-11-09
AC POWER SUPPLY	EVERFINE	VPS1030 PWM	1012017	2022-11-16	2023-11-15
Digital CC&CV DC Power Supply	EVERFINE	WY12010	1009009	2022-11-10	2023-11-09

Device	Manufacture	Model No	Serial No	Calibration date	Calibration due date
Digital power meter	YOKOGAWA	WT-210	91j926132	2022-11-10	2023-11-09
full-field speed goniophotometer	EVERFINE	GO-R5000	YG108492N10120001	2022-11-10	2023-11-09
wireless remote thermohygrometer	N/A	AOK-5017B	N/A	2022-11-10	2023-11-09
Standard Light Source	EVERFINE	D908	1012003	2023-05-12	2025-05-11

Statement of Traceability: Bay Area Compliance Laboratories Corp. (Shenzhen) attested that all calibration has been performed using suitable standards traceable to National Primary Standards and International System of Units (SI).

## 4. Test Method

Product was tested with no seasoning. All stabilization and measurements were made in compliance with IES LM-79-08. The product was operated at rated voltage or at voltage required by manufacturer. The ambient temperature of the sample was maintained at  $25^{\circ}\text{C} \pm 1^{\circ}\text{C}$  during measurement. And relative humidity is less than 65%.

### Integrating Sphere System

The system includes AC power source, digital power meter, DC power supply, Spectroradiometer, and integrating sphere. The integrating sphere system is calibrated by standard spectrum light source before measurement.

$4\pi$  geometry was used during measurement. The product was operated in its intended orientation in application and was recorded in this report.

The uncertainty of the light output (luminous flux) measurements is  $U=2.1\%$  ( $K=2$ ), at the 95% confidence level. The uncertainty of the correlated color temperature measurements is  $U=22\text{K}$  ( $K=2$ ), at the 95% confidence level. The uncertainty of the CRI is  $U=2.1(K=2)$ , at the 95% confidence level.

The uncertainty of power meter AC current  $U=0.19\%$  of rdg, AC Voltage  $U=0.18\%$  of rdg, Power  $U=0.46\%$  ( $K=2$ ), at the 95% confidence level.

### Goniophotometer System

The goniophotometer system is calibrated by standard light source before measurement.

Type C goniophotometer was used for measuring total luminous flux, luminous intensity distribution, and color spatial uniformity. The product was operated in its intended orientation in application and was recorded in this report. The vertical angle ( $\gamma$ ) test intervals were set no more than 1 degree while data for 5 degree intervals is reported. The horizontal angle (C plane) test intervals were set no more than 22.5 degree.

The uncertainty of the luminous intensity is  $U=2.00\%$  ( $K=2$ ), at the 95% confidence level.

### Additional Test

The Additional Test item may not be covered by IESNA LM-79-2008. Additional test including power factor, off-state power and THD, was measured by Digital Power Meter after stabilized at  $25^{\circ}\text{C} \pm 1^{\circ}\text{C}$ . Test voltage for THD and power factor test would be equal to rated voltage or, in case of a voltage range, maximum value of that range.

The uncertainty of power meter AC current  $U=0.19\%$  of rdg, AC Voltage  $U=0.18\%$  of rdg, Power  $U=0.46\%$  ( $K=2$ ), at the 95% confidence level.

### Fidelity Index and Gamut Index Calculation

The  $R_i$ ,  $R_g$  was calculated according to IES TM-30-18 by using calculation tools. The calculation was based on the measured SPD from 380nm to 780nm with 1nm intervals. All the colors in this report is for reference only.

## 5. Test Result

### [Integrating Sphere System]

The Stabilization time: **30 minutes**

Total operating time for integrating sphere test: **1.0 hour**

Test orientation: **Base Up**


### Photometric and Electrical Measurement Result







Voltage (V)	Frequency (Hz)	Current (A)	Power (W)	Power Factor	Luminous Flux(lm)	Efficacy (lm/W)
120.0	60	0.1289	15.36	0.9932	1598.0	104.01

Radiant Flux (W)	CCT (K)	Duv	x	y	u'	v'
5.7446	4021	0.00283	0.3814	0.3835	0.2231	0.5047


### Color Rendering Index

<b>Ra</b>			
96.1			
<b>R1</b>	<b>R2</b>	<b>R3</b>	<b>R4</b>
98	99	100	93
<b>R5</b>	<b>R6</b>	<b>R7</b>	<b>R8</b>
95	98	93	93
<b>R9</b>	<b>R10</b>	<b>R11</b>	<b>R12</b>
91	98	95	74
<b>R13</b>	<b>R14</b>	<b>R15</b>	
99	99	95	






# Relative Spectral Power Distribution




nm	mW	nm	mW	nm	mW	nm	mW	nm	mW
380	5.510E-01	421	1.027E+00	462	2.510E+01	503	1.700E+01	544	2.212E+01
381	5.317E-01	422	1.135E+00	463	2.403E+01	504	1.718E+01	545	2.218E+01
382	4.259E-01	423	1.257E+00	464	2.301E+01	505	1.734E+01	546	2.222E+01
383	3.930E-01	424	1.403E+00	465	2.203E+01	506	1.757E+01	547	2.227E+01
384	3.706E-01	425	1.555E+00	466	2.121E+01	507	1.773E+01	548	2.232E+01
385	3.413E-01	426	1.716E+00	467	2.051E+01	508	1.790E+01	549	2.237E+01
386	3.180E-01	427	1.902E+00	468	1.993E+01	509	1.806E+01	550	2.238E+01
387	2.725E-01	428	2.100E+00	469	1.945E+01	510	1.823E+01	551	2.242E+01
388	2.520E-01	429	2.319E+00	470	1.906E+01	511	1.836E+01	552	2.245E+01
389	2.395E-01	430	2.552E+00	471	1.871E+01	512	1.854E+01	553	2.245E+01
390	2.334E-01	431	2.816E+00	472	1.836E+01	513	1.869E+01	554	2.248E+01
391	2.047E-01	432	3.091E+00	473	1.801E+01	514	1.882E+01	555	2.250E+01
392	2.075E-01	433	3.404E+00	474	1.768E+01	515	1.899E+01	556	2.250E+01
393	2.010E-01	434	3.729E+00	475	1.718E+01	516	1.914E+01	557	2.253E+01
394	1.780E-01	435	4.095E+00	476	1.676E+01	517	1.926E+01	558	2.253E+01
395	1.836E-01	436	4.490E+00	477	1.632E+01	518	1.940E+01	559	2.253E+01
396	1.901E-01	437	4.937E+00	478	1.587E+01	519	1.955E+01	560	2.253E+01
397	1.810E-01	438	5.423E+00	479	1.545E+01	520	1.966E+01	561	2.253E+01
398	1.733E-01	439	5.955E+00	480	1.511E+01	521	1.979E+01	562	2.253E+01
399	1.751E-01	440	6.519E+00	481	1.481E+01	522	1.994E+01	563	2.252E+01
400	1.742E-01	441	7.128E+00	482	1.461E+01	523	2.007E+01	564	2.252E+01
401	1.834E-01	442	7.810E+00	483	1.443E+01	524	2.017E+01	565	2.252E+01
402	1.839E-01	443	8.521E+00	484	1.439E+01	525	2.029E+01	566	2.250E+01
403	1.914E-01	444	9.348E+00	485	1.436E+01	526	2.043E+01	567	2.251E+01
404	2.026E-01	445	1.022E+01	486	1.442E+01	527	2.054E+01	568	2.252E+01
405	2.169E-01	446	1.124E+01	487	1.447E+01	528	2.065E+01	569	2.249E+01
406	2.314E-01	447	1.231E+01	488	1.453E+01	529	2.075E+01	570	2.249E+01
407	2.479E-01	448	1.356E+01	489	1.469E+01	530	2.088E+01	571	2.249E+01
408	2.730E-01	449	1.493E+01	490	1.481E+01	531	2.099E+01	572	2.247E+01
409	2.939E-01	450	1.643E+01	491	1.495E+01	532	2.110E+01	573	2.248E+01
410	3.227E-01	451	1.807E+01	492	1.510E+01	533	2.121E+01	574	2.248E+01
411	3.458E-01	452	1.970E+01	493	1.525E+01	534	2.130E+01	575	2.248E+01
412	3.877E-01	453	2.142E+01	494	1.539E+01	535	2.140E+01	576	2.251E+01
413	4.280E-01	454	2.300E+01	495	1.553E+01	536	2.150E+01	577	2.250E+01
414	4.822E-01	455	2.445E+01	496	1.569E+01	537	2.159E+01	578	2.249E+01
415	5.268E-01	456	2.567E+01	497	1.587E+01	538	2.168E+01	579	2.254E+01
416	6.011E-01	457	2.649E+01	498	1.605E+01	539	2.177E+01	580	2.256E+01
417	6.668E-01	458	2.694E+01	499	1.620E+01	540	2.182E+01	581	2.257E+01
418	7.438E-01	459	2.702E+01	500	1.640E+01	541	2.194E+01	582	2.261E+01
419	8.317E-01	460	2.666E+01	501	1.657E+01	542	2.199E+01	583	2.265E+01
420	9.187E-01	461	2.602E+01	502	1.677E+01	543	2.207E+01	584	2.268E+01

nm	mW	nm	mW	nm	mW	nm	mW	nm	mW
585	2.274E+01	626	2.636E+01	667	1.978E+01	708	8.606E+00	749	2.835E+00
586	2.278E+01	627	2.636E+01	668	1.950E+01	709	8.398E+00	750	2.755E+00
587	2.283E+01	628	2.638E+01	669	1.920E+01	710	8.187E+00	751	2.676E+00
588	2.292E+01	629	2.636E+01	670	1.891E+01	711	7.989E+00	752	2.602E+00
589	2.302E+01	630	2.636E+01	671	1.862E+01	712	7.796E+00	753	2.535E+00
590	2.311E+01	631	2.630E+01	672	1.832E+01	713	7.596E+00	754	2.459E+00
591	2.317E+01	632	2.630E+01	673	1.803E+01	714	7.418E+00	755	2.394E+00
592	2.327E+01	633	2.625E+01	674	1.771E+01	715	7.231E+00	756	2.327E+00
593	2.337E+01	634	2.620E+01	675	1.742E+01	716	7.044E+00	757	2.256E+00
594	2.342E+01	635	2.612E+01	676	1.713E+01	717	6.865E+00	758	2.193E+00
595	2.353E+01	636	2.608E+01	677	1.682E+01	718	6.691E+00	759	2.131E+00
596	2.361E+01	637	2.598E+01	678	1.653E+01	719	6.503E+00	760	2.075E+00
597	2.370E+01	638	2.588E+01	679	1.623E+01	720	6.344E+00	761	2.011E+00
598	2.379E+01	639	2.576E+01	680	1.594E+01	721	6.191E+00	762	1.959E+00
599	2.389E+01	640	2.565E+01	681	1.565E+01	722	6.028E+00	763	1.901E+00
600	2.403E+01	641	2.554E+01	682	1.535E+01	723	5.867E+00	764	1.842E+00
601	2.412E+01	642	2.540E+01	683	1.505E+01	724	5.708E+00	765	1.791E+00
602	2.423E+01	643	2.527E+01	684	1.475E+01	725	5.557E+00	766	1.740E+00
603	2.438E+01	644	2.512E+01	685	1.447E+01	726	5.415E+00	767	1.689E+00
604	2.448E+01	645	2.496E+01	686	1.419E+01	727	5.264E+00	768	1.644E+00
605	2.458E+01	646	2.479E+01	687	1.390E+01	728	5.122E+00	769	1.595E+00
606	2.471E+01	647	2.463E+01	688	1.363E+01	729	4.981E+00	770	1.549E+00
607	2.483E+01	648	2.443E+01	689	1.335E+01	730	4.837E+00	771	1.507E+00
608	2.494E+01	649	2.424E+01	690	1.307E+01	731	4.717E+00	772	1.462E+00
609	2.506E+01	650	2.405E+01	691	1.280E+01	732	4.583E+00	773	1.421E+00
610	2.515E+01	651	2.383E+01	692	1.253E+01	733	4.458E+00	774	1.381E+00
611	2.527E+01	652	2.363E+01	693	1.226E+01	734	4.333E+00	775	1.343E+00
612	2.538E+01	653	2.341E+01	694	1.199E+01	735	4.214E+00	776	1.306E+00
613	2.550E+01	654	2.320E+01	695	1.173E+01	736	4.093E+00	777	1.267E+00
614	2.560E+01	655	2.295E+01	696	1.146E+01	737	3.979E+00	778	1.234E+00
615	2.569E+01	656	2.271E+01	697	1.121E+01	738	3.866E+00	779	1.221E+00
616	2.578E+01	657	2.247E+01	698	1.095E+01	739	3.757E+00	780	1.223E+00
617	2.590E+01	658	2.222E+01	699	1.071E+01	740	3.653E+00		
618	2.596E+01	659	2.198E+01	700	1.046E+01	741	3.549E+00		
619	2.604E+01	660	2.173E+01	701	1.021E+01	742	3.452E+00		
620	2.609E+01	661	2.145E+01	702	9.969E+00	743	3.353E+00		
621	2.619E+01	662	2.117E+01	703	9.738E+00	744	3.257E+00		
622	2.621E+01	663	2.091E+01	704	9.500E+00	745	3.175E+00		
623	2.627E+01	664	2.064E+01	705	9.275E+00	746	3.079E+00		
624	2.632E+01	665	2.034E+01	706	9.057E+00	747	2.999E+00		
625	2.634E+01	666	2.007E+01	707	8.826E+00	748	2.919E+00		

### CIE 1931 x y Chromaticity Diagram



### 7-Step Chromaticity Quadrangles





The Stabilization time: **30 minutes**

Total operating time for luminous intensity distribution: **1.0hour**

Test orientation: **Base Up**


### Electrical Measurement

Input Voltage (V)	Frequency (Hz)	Input Current (A)	Power (W)	Power Factor
120.00	60	0.1288	15.350	0.9931

### Photometric Measurement

Luminous Flux (lm)	Efficacy (lm/W)	I <sub>max</sub> (cd)	S/MH (C0/180)	S/MH (C90/270)
1598.13	104.11	19914.0	0.17	0.19

### Luminous Intensity Distribution



	C0/180	C45/225	C90/270	C135/315	AVG.
Beam Angle (50% I <sub>max</sub> ):	11.3	11.2	11.2	11.2	11.2
Field Angle (10% I <sub>max</sub> ):	26.7	26.7	26.6	26.6	26.7

**Luminous Intensity (cd) Distribution Data**

C y	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°
0.0°	19389	19389	19389	19389	19389	19389	19389	19389
5.0°	13592	13726	13378	12623	11586	10586	9694	9142
10.0°	4734	4812	4676	4403	3842	3540	3292	3139
15.0°	1685	1720	1692	1627	1514	1408	1332	1293
20.0°	718	751	750	721	663	606	587	579
25.0°	307	327	326	312	280	254	240	234
30.0°	144	148	145	137	129	123	120	119
35.0°	100	99	96	93	90	89	89	89
40.0°	81	81	79	77	76	74	73	72
45.0°	66	66	65	64	63	61	61	60
50.0°	54	53	52	51	50	50	49	48
55.0°	42	42	41	40	39	39	38	38
60.0°	34	33	33	32	32	31	31	31
65.0°	27	27	27	26	26	25	25	25
70.0°	22	22	21	21	20	20	19	19
75.0°	17	16	16	15	15	15	14	14
80.0°	11	11	11	10	10	9	9	9
85.0°	6	6	6	5	5	5	4	4
90.0°	2	2	2	2	1	1	1	1
95.0°	0	0	0	0	0	0	0	0
100.0°	0	0	0	0	0	0	0	0
105.0°	0	0	0	0	0	0	0	0
110.0°	0	0	0	0	0	0	0	0
115.0°	0	0	0	0	0	0	0	0
120.0°	0	0	0	0	0	0	0	0
125.0°	0	0	0	0	0	0	0	0
130.0°	0	0	0	0	0	0	0	0
135.0°	0	0	0	0	0	0	0	0
140.0°	1	1	1	1	1	1	1	1
145.0°	3	2	3	3	3	3	3	3
150.0°	4	4	4	4	4	4	5	5
155.0°	6	6	5	6	6	6	6	6
160.0°	6	6	6	6	6	6	6	6
165.0°	6	6	6	6	6	6	6	6
170.0°	5	5	5	5	5	5	4	4
175.0°	3	3	3	3	3	3	3	3
180.0°	2	2	2	2	1	1	1	1

**Luminous Intensity (cd) Distribution Data (cont.)**

C Y	180°	202.5°	225°	247.5°	270°	292.5°	315°	337.5°
0.0°	19389	19389	19389	19389	19389	19389	19389	19389
5.0°	9458	9287	9375	9789	10508	11603	12653	13780
10.0°	3212	3180	3189	3275	3449	3733	4106	4519
15.0°	1370	1358	1345	1359	1410	1493	1612	1698
20.0°	604	603	596	588	588	608	650	717
25.0°	253	254	254	248	245	250	267	297
30.0°	122	121	120	120	121	125	139	149
35.0°	88	87	87	88	88	91	94	99
40.0°	72	72	72	72	73	75	78	81
45.0°	60	60	60	60	61	63	65	67
50.0°	49	48	48	48	49	51	53	55
55.0°	38	38	37	38	39	40	41	42
60.0°	31	30	30	30	31	32	33	34
65.0°	25	24	24	24	25	26	26	27
70.0°	20	19	19	19	20	20	21	22
75.0°	14	14	14	14	15	15	16	16
80.0°	9	9	9	9	9	10	11	11
85.0°	4	4	4	4	5	5	6	6
90.0°	1	1	1	1	1	1	2	2
95.0°	0	0	0	0	0	0	0	0
100.0°	0	0	0	0	0	0	0	0
105.0°	0	0	0	0	0	0	0	0
110.0°	0	0	0	0	0	0	0	0
115.0°	0	0	0	0	0	0	0	0
120.0°	0	0	0	0	0	0	0	0
125.0°	0	0	0	0	0	0	0	0
130.0°	0	0	0	0	0	0	0	0
135.0°	0	0	0	0	0	0	0	0
140.0°	0	0	0	0	0	0	0	0
145.0°	1	1	1	1	1	1	1	1
150.0°	1	1	1	1	1	1	1	1
155.0°	1	1	1	1	1	1	1	1
160.0°	1	1	1	1	1	1	1	1
165.0°	1	1	1	1	1	1	1	1
170.0°	1	1	1	1	1	1	1	1
175.0°	1	1	1	1	1	1	1	1
180.0°	2	2	2	2	2	2	1	1

### Zonal Lumen Density Measurement

Deg	Flux (lm)	%
0-5	357.3	22.36
5-10	466.6	29.19
10-15	278.8	17.45
15-20	163.5	10.23
20-25	90.2	5.64
25-30	47.3	2.96
30-35	31.5	1.97
35-40	27.6	1.73
40-45	25.5	1.60
45-50	22.9	1.43
50-55	19.3	1.21
55-60	16.3	1.02
60-65	13.9	0.87
65-70	11.6	0.72
70-75	9.2	0.58
75-80	6.6	0.41
80-85	4.0	0.25
85-90	1.7	0.11
90-95	0.2	0.01
95-100	0.0	0.00
100-105	0.0	0.00
105-110	0.0	0.00
110-115	0.0	0.01
115-120	0.0	0.00
120-125	0.0	0.00
125-130	0.0	0.00
130-135	0.1	0.00
135-140	0.2	0.01
140-145	0.4	0.03
145-150	0.7	0.04
150-155	0.8	0.05
155-160	0.8	0.05
160-165	0.6	0.03
165-170	0.4	0.03
170-175	0.2	0.01
175-180	0.0	0.00

Deg	Flux (lm)	%
0-5	357.3	22.36
0-10	823.9	51.55
0-15	1102.7	69.00
0-20	1266.1	79.23
0-25	1356.4	84.87
0-30	1403.7	87.83
0-35	1435.2	89.80
0-40	1462.8	91.53
0-45	1488.3	93.13
0-50	1511.2	94.56
0-55	1530.6	95.77
0-60	1546.9	96.79
0-65	1560.7	97.66
0-70	1572.3	98.38
0-75	1581.5	98.96
0-80	1588.1	99.37
0-85	1592.1	99.62
0-90	1593.8	99.73
0-95	1594.0	99.74
0-100	1594.0	99.74
0-105	1594.0	99.74
0-110	1594.0	99.74
0-115	1594.1	99.75
0-120	1594.1	99.75
0-125	1594.1	99.75
0-130	1594.1	99.75
0-135	1594.2	99.75
0-140	1594.3	99.76
0-145	1594.7	99.79
0-150	1595.4	99.83
0-155	1596.2	99.88
0-160	1596.9	99.93
0-165	1597.5	99.96
0-170	1597.9	99.99
0-175	1598.1	100.00
0-180	1598.1	100.00

**[Additional Test]**

Test Item	Test Voltage (V)	Frequency (Hz)	Test Result
Total Harmonic Distortion:	120.0	60	11.68%

**6. Product Photo**



## Directions

1. The information marked "superscript #" is provided by the applicant, the laboratory is not responsible for its authenticity and this information can affect the validity of the result in the test report.
2. This report includes some test methods are not in NVLAP accreditation scope marked \*.
3. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.
4. Otherwise required by the applicant or Product Regulations, Decision Rule in this report did not consider the uncertainty.
5. The extended uncertainty given in this report is obtained by combining the standard uncertainty times the coverage factor  $K=2$  with the 95% confidence interval.
6. This report cannot be reproduced except in full, without prior written approval of the Company.
7. This report is valid only with a valid digital signature. The digital signature may be available only under the Adobe software above version 7.0.

\*\*\*\*\*END OF REPORT\*\*\*\*\*