



# IES LM-79-08

## MEASUREMENT AND TEST REPORT

For

### GREEN CREATIVE LTD

Room 3603, Level 36, Tower 1, Enterprise Square Five, 38 Wang Chiu Road, Kowloon Bay, KL, Hong Kong

**Test Model: 34HID/830/277V/E26/DIM**

<b>Report Type:</b>	Electrical and Photometric tests including: Luminous Flux, Chromaticity, Luminous Intensity Distribution
<b>Reviewed By:</b>	George Chen <i>George Chen</i>
<b>Report Number:</b>	KS2210713-47090E-10-1
<b>Test Date:</b>	2021-07-14 to 2021-07-15
<b>Report Date:</b>	2021-12-10
<b>Approved by:</b>	Bill Xiong / EE Engineer
<b>Prepared By:</b>	Bay Area Compliance Laboratories Corp. (Dongguan). No.12, Pulong East 1 <sup>st</sup> Road, Tangxia Town, Dongguan, Guangdong, China. Tel: +86-0769-86858888 Fax: +86-0769-86858588

## 1. Product Description

### General Information:

Two test samples were in good condition and received on 2021-07-13. One was tested in integrating sphere and the other was tested in goniophotometer

Model Tested: 34HID/830/277V/E26/DIM  
Manufacturer: GREEN CREATIVE LTD  
Product Designation: Omnidirectional LED Lamp  
Burning Time Before Test: 0hour(For New Products)

### #Rated Values:

Rated Voltage/Frequency: 120-277V AC, 50/60Hz  
Rated Power: 34W  
Nominal CCT: 3000K  
Nominal Lumen Output: 4500lm

## 2. Standards Used

- IES LM-79-08: Approved Method: Electrical & Photometric Measurement of Solid-state Lighting Products
- ANSI C82.77-10-2014: Harmonic Emission Limits – Related Power Quality Requirements for Lighting
- IES TM-30-18: IES Method for Evaluating Light Source Color Rendition (This method is not in IAS accreditation scope)

## 3. Description of Test Equipment

Device	Manufacture	Model No	Serial No	Calibration date	Calibration due date
1.5m integrating sphere	SENSING	1.5m	NA	2021-06-30	2022-06-29
Digital power meter	EVERFINE	PF9811	G135717CN1361159	2021-09-23	2022-09-22
High-precision rapid spectral radiometer	EVERFINE	HAAS-2000	N/A	2021-06-30	2022-06-29
Precision frequency power supply	ALL Power	APW-105N	970663	2021-01-04	2022-01-03
Standard Light Source	EVERFINE	D204	N/A	2021-10-15	2022-10-14
thermometer	SENSING	NA	NA	2021-04-27	2022-04-26
Programmable Precision DC Power Supply	EVERFINE	WY5015	11060010	2021-06-30	2022-06-29
AC POWER SUPPLY	EVERFINE	VPS1030 PWM	1012017	2021-01-04	2022-01-03
Digital CC&CV DC Power Supply	EVERFINE	WY12010	1009009	2021-01-04	2022-01-03
Digital power meter	YOKOGAWA	WT-210	91j926132	2021-01-04	2022-01-03
full-field speed goniophotometer	EVERFINE	GO-R5000	YG108492N10120001	2021-03-12	2022-03-11
wireless remote thermohygrometer	N/A	433MHz	N/A	2021-04-27	2022-04-26
Standard Light Source	EVERFINE	D908	1012003	2021-10-15	2022-10-14

Statement of Traceability: Bay Area Compliance Laboratories Corp. (Dongguan) attested that all calibration has been performed using suitable standards traceable to National Primary Standards and International System of Units (SI).

#### 4. Test Method

Product was tested with no seasoning. All stabilization and measurements were made in compliance with IES LM-79-08. The product was operated at rated voltage or at voltage required by manufacturer. The ambient temperature of the sample was maintained at  $25^{\circ}\text{C} \pm 1^{\circ}\text{C}$  during measurement. And relative humidity is less than 65%.

##### **Integrating Sphere System**

The system includes AC power source, digital power meter, DC power supply, Spectroradiometer, and integrating sphere. The integrating sphere system is calibrated by standard spectrum light source before measurement.

$4\pi$  geometry was used during measurement. The product was operated in its intended orientation in application and was recorded in this report.

The uncertainty of the light output (luminous flux) measurements is  $U=2.1\%$  ( $K=2$ ), at the 95% confidence level. The uncertainty of the correlated color temperature measurements is  $U=21\text{K}$  ( $K=2$ ), at the 95% confidence level. The uncertainty of the CRI is  $U=2.1(K=2)$ , at the 95% confidence level.

The uncertainty of power meter AC current  $U=0.19\%$  of rdg, AC Voltage  $U=0.17\%$  of rdg, Power  $U=0.48\%$  ( $K=2$ ), at the 95% confidence level.

##### **Goniophotometer System**

The goniophotometer system is calibrated by standard light source before measurement.

Type C goniophotometer was used for measuring total luminous flux, luminous intensity distribution, and color spatial uniformity. The product was operated in its intended orientation in application and was recorded in this report. The vertical angle ( $\gamma$ ) test intervals were set no more than 1 degree while data for 5 degree intervals is reported. The horizontal angle (C plane) test intervals were set no more than 22.5 degree.

The uncertainty of the luminous intensity is  $U=2.00\%$  ( $K=2$ ), at the 95% confidence level.

##### **Fidelity Index and Gamut Index Calculation**

The  $R_i$ ,  $R_g$  was calculated according to IES TM-30-18 by using calculation tools. The calculation was based on the measured SPD from 380nm to 780nm with 1nm intervals. All the colors in this report is for reference only.

## 5. Test Result

### [Integrating Sphere System]

Total operating time for integrating sphere test: **1.0 hour**

Test orientation: **Base up**


### Photometric and Electrical Measurement Result


Voltage (V)	Frequency (Hz)	Current (A)	Power (W)	Power Factor	Luminous Flux(lm)	Efficacy (lm/W)
120.0	60	0.2831	33.91	0.9984	4824.1	142.28

Radiant Flux (W)	CCT (K)	Duv	x	y	u'	v'
14.607	2987	0.000731	0.4389	0.4066	0.2508	0.5227


### Color Rendering Index

<b>Ra</b>			
82.8			
<b>R1</b>	<b>R2</b>	<b>R3</b>	<b>R4</b>
81	92	95	80
<b>R5</b>	<b>R6</b>	<b>R7</b>	<b>R8</b>
82	91	82	58
<b>R9</b>	<b>R10</b>	<b>R11</b>	<b>R12</b>
6	83	80	74
<b>R13</b>	<b>R14</b>	<b>R15</b>	
84	98	73	






Relative Spectral Power Distribution




nm	mW	nm	mW	nm	mW	nm	mW	nm	mW
380	1.623E+00	421	2.580E+00	462	3.344E+01	503	3.592E+01	544	5.515E+01
381	1.271E+00	422	2.898E+00	463	3.270E+01	504	3.660E+01	545	5.565E+01
382	1.031E+00	423	3.128E+00	464	3.192E+01	505	3.734E+01	546	5.628E+01
383	1.063E+00	424	3.511E+00	465	3.131E+01	506	3.801E+01	547	5.690E+01
384	9.759E-01	425	3.910E+00	466	3.048E+01	507	3.853E+01	548	5.746E+01
385	1.047E+00	426	4.350E+00	467	2.965E+01	508	3.915E+01	549	5.798E+01
386	6.299E-01	427	4.693E+00	468	2.889E+01	509	3.962E+01	550	5.868E+01
387	7.638E-01	428	5.291E+00	469	2.800E+01	510	4.024E+01	551	5.932E+01
388	7.152E-01	429	5.848E+00	470	2.695E+01	511	4.074E+01	552	5.994E+01
389	6.993E-01	430	6.476E+00	471	2.588E+01	512	4.130E+01	553	6.089E+01
390	6.116E-01	431	7.008E+00	472	2.499E+01	513	4.195E+01	554	6.137E+01
391	6.201E-01	432	7.864E+00	473	2.419E+01	514	4.237E+01	555	6.220E+01
392	5.859E-01	433	8.705E+00	474	2.334E+01	515	4.284E+01	556	6.292E+01
393	6.821E-01	434	9.478E+00	475	2.279E+01	516	4.329E+01	557	6.376E+01
394	6.250E-01	435	1.055E+01	476	2.225E+01	517	4.377E+01	558	6.464E+01
395	5.926E-01	436	1.158E+01	477	2.203E+01	518	4.424E+01	559	6.539E+01
396	5.770E-01	437	1.272E+01	478	2.199E+01	519	4.470E+01	560	6.631E+01
397	5.154E-01	438	1.408E+01	479	2.192E+01	520	4.508E+01	561	6.713E+01
398	4.648E-01	439	1.555E+01	480	2.207E+01	521	4.558E+01	562	6.802E+01
399	5.365E-01	440	1.737E+01	481	2.221E+01	522	4.587E+01	563	6.890E+01
400	4.740E-01	441	1.929E+01	482	2.257E+01	523	4.614E+01	564	6.987E+01
401	5.126E-01	442	2.127E+01	483	2.296E+01	524	4.659E+01	565	7.087E+01
402	5.357E-01	443	2.381E+01	484	2.335E+01	525	4.695E+01	566	7.191E+01
403	5.285E-01	444	2.645E+01	485	2.378E+01	526	4.736E+01	567	7.283E+01
404	5.537E-01	445	2.931E+01	486	2.414E+01	527	4.781E+01	568	7.377E+01
405	6.174E-01	446	3.242E+01	487	2.467E+01	528	4.815E+01	569	7.485E+01
406	6.522E-01	447	3.580E+01	488	2.523E+01	529	4.851E+01	570	7.579E+01
407	6.269E-01	448	3.920E+01	489	2.564E+01	530	4.905E+01	571	7.683E+01
408	6.373E-01	449	4.200E+01	490	2.634E+01	531	4.929E+01	572	7.793E+01
409	7.093E-01	450	4.448E+01	491	2.692E+01	532	4.973E+01	573	7.887E+01
410	7.025E-01	451	4.636E+01	492	2.772E+01	533	5.009E+01	574	7.997E+01
411	7.502E-01	452	4.733E+01	493	2.833E+01	534	5.054E+01	575	8.103E+01
412	9.648E-01	453	4.749E+01	494	2.909E+01	535	5.092E+01	576	8.206E+01
413	1.012E+00	454	4.702E+01	495	3.000E+01	536	5.134E+01	577	8.320E+01
414	1.167E+00	455	4.565E+01	496	3.063E+01	537	5.185E+01	578	8.419E+01
415	1.265E+00	456	4.368E+01	497	3.141E+01	538	5.212E+01	579	8.517E+01
416	1.500E+00	457	4.187E+01	498	3.220E+01	539	5.270E+01	580	8.623E+01
417	1.679E+00	458	3.951E+01	499	3.296E+01	540	5.310E+01	581	8.722E+01
418	1.871E+00	459	3.772E+01	500	3.371E+01	541	5.361E+01	582	8.818E+01
419	2.127E+00	460	3.575E+01	501	3.443E+01	542	5.410E+01	583	8.903E+01
420	2.318E+00	461	3.464E+01	502	3.525E+01	543	5.455E+01	584	9.003E+01

nm	mW	nm	mW	nm	mW	nm	mW	nm	mW
585	9.097E+01	626	8.628E+01	667	3.760E+01	708	1.112E+01	749	3.102E+00
586	9.167E+01	627	8.527E+01	668	3.659E+01	709	1.083E+01	750	3.025E+00
587	9.259E+01	628	8.416E+01	669	3.563E+01	710	1.049E+01	751	2.918E+00
588	9.343E+01	629	8.310E+01	670	3.471E+01	711	1.021E+01	752	2.858E+00
589	9.425E+01	630	8.196E+01	671	3.372E+01	712	9.892E+00	753	2.793E+00
590	9.487E+01	631	8.068E+01	672	3.278E+01	713	9.587E+00	754	2.685E+00
591	9.555E+01	632	7.953E+01	673	3.196E+01	714	9.272E+00	755	2.633E+00
592	9.620E+01	633	7.825E+01	674	3.112E+01	715	8.952E+00	756	2.523E+00
593	9.677E+01	634	7.708E+01	675	3.022E+01	716	8.742E+00	757	2.469E+00
594	9.719E+01	635	7.586E+01	676	2.945E+01	717	8.393E+00	758	2.389E+00
595	9.778E+01	636	7.461E+01	677	2.861E+01	718	8.199E+00	759	2.309E+00
596	9.820E+01	637	7.348E+01	678	2.782E+01	719	7.927E+00	760	2.263E+00
597	9.840E+01	638	7.207E+01	679	2.696E+01	720	7.694E+00	761	2.200E+00
598	9.886E+01	639	7.083E+01	680	2.624E+01	721	7.414E+00	762	2.143E+00
599	9.903E+01	640	6.953E+01	681	2.548E+01	722	7.217E+00	763	2.058E+00
600	9.932E+01	641	6.827E+01	682	2.477E+01	723	6.937E+00	764	2.007E+00
601	9.953E+01	642	6.702E+01	683	2.411E+01	724	6.710E+00	765	1.981E+00
602	9.967E+01	643	6.578E+01	684	2.337E+01	725	6.556E+00	766	1.893E+00
603	9.960E+01	644	6.445E+01	685	2.270E+01	726	6.308E+00	767	1.860E+00
604	9.968E+01	645	6.328E+01	686	2.197E+01	727	6.179E+00	768	1.782E+00
605	9.950E+01	646	6.188E+01	687	2.135E+01	728	5.930E+00	769	1.743E+00
606	9.945E+01	647	6.050E+01	688	2.081E+01	729	5.770E+00	770	1.655E+00
607	9.904E+01	648	5.940E+01	689	2.016E+01	730	5.570E+00	771	1.628E+00
608	9.894E+01	649	5.812E+01	690	1.950E+01	731	5.433E+00	772	1.592E+00
609	9.841E+01	650	5.687E+01	691	1.901E+01	732	5.295E+00	773	1.540E+00
610	9.813E+01	651	5.566E+01	692	1.839E+01	733	5.118E+00	774	1.485E+00
611	9.763E+01	652	5.429E+01	693	1.791E+01	734	4.961E+00	775	1.468E+00
612	9.719E+01	653	5.308E+01	694	1.730E+01	735	4.762E+00	776	1.395E+00
613	9.688E+01	654	5.196E+01	695	1.681E+01	736	4.629E+00	777	1.403E+00
614	9.623E+01	655	5.079E+01	696	1.625E+01	737	4.472E+00	778	1.350E+00
615	9.566E+01	656	4.958E+01	697	1.578E+01	738	4.372E+00	779	1.378E+00
616	9.520E+01	657	4.846E+01	698	1.530E+01	739	4.219E+00	780	1.381E+00
617	9.446E+01	658	4.724E+01	699	1.486E+01	740	4.088E+00		
618	9.365E+01	659	4.612E+01	700	1.436E+01	741	4.001E+00		
619	9.277E+01	660	4.507E+01	701	1.395E+01	742	3.862E+00		
620	9.204E+01	661	4.383E+01	702	1.348E+01	743	3.778E+00		
621	9.126E+01	662	4.283E+01	703	1.305E+01	744	3.630E+00		
622	9.039E+01	663	4.172E+01	704	1.266E+01	745	3.488E+00		
623	8.934E+01	664	4.073E+01	705	1.234E+01	746	3.393E+00		
624	8.834E+01	665	3.957E+01	706	1.187E+01	747	3.303E+00		
625	8.731E+01	666	3.862E+01	707	1.151E+01	748	3.215E+00		

CIE 1931 x y Chromaticity Diagram



7-Step Chromaticity Quadrangles





### [Goniophotometer System]

Total operating time for luminous intensity distribution: **1.0 hour**

Test orientation: **Base up**


### Electrical Measurement

Input Voltage (V)	Frequency (Hz)	Input Current (A)	Power (W)	Power Factor
120.0	60	0.2832	33.93	0.9985

### Photometric Measurement

Luminous Flux (lm)	Efficacy (lm/W)	$I_{max}$ (cd)	S/MH (C0/180)	S/MH (C90/270)
4834.61	142.49	591.7	1.46	1.5

### Luminous Intensity Distribution



	C0/180	C45/225	C90/270	C135/315	AVG.
Beam Angle (50% $I_{max}$ ):	226.5	227.7	228.5	227.0	227.4
Field Angle (10% $I_{max}$ ):	332.6	332.9	333.3	332.8	332.9

Luminous Intensity (cd) Distribution Data

C y	0°	22.5°	45°	67.5°	90°	112.5°	135°	157.5°
0.0°	587	587	587	587	587	587	587	587
5.0°	588	588	589	587	587	585	586	584
10.0°	590	590	589	587	586	584	583	582
15.0°	591	591	589	587	585	583	581	579
20.0°	591	590	590	586	583	581	577	575
25.0°	591	590	588	584	581	577	574	571
30.0°	589	588	586	582	578	573	569	567
35.0°	586	585	583	579	575	569	564	561
40.0°	582	580	579	573	569	563	558	554
45.0°	574	573	572	567	561	555	549	545
50.0°	565	565	563	558	552	546	540	536
55.0°	555	553	552	546	540	534	528	524
60.0°	541	540	538	533	528	522	515	510
65.0°	525	524	523	518	513	506	500	495
70.0°	507	507	505	501	496	489	484	478
75.0°	488	487	486	482	478	471	465	461
80.0°	466	466	465	462	457	451	445	441
85.0°	445	444	443	440	436	430	424	421
90.0°	421	421	420	418	414	408	402	399
95.0°	396	397	397	394	390	385	380	377
100.0°	371	372	371	369	366	362	357	354
105.0°	346	346	346	344	342	338	333	331
110.0°	320	321	320	319	318	313	310	308
115.0°	294	295	295	294	292	289	286	284
120.0°	269	270	270	268	268	265	262	260
125.0°	243	244	245	244	243	241	238	237
130.0°	218	219	219	219	218	217	215	213
135.0°	194	195	196	195	195	193	191	191
140.0°	170	171	171	171	171	170	169	168
145.0°	147	148	149	149	149	148	147	146
150.0°	124	125	126	126	127	126	125	125
155.0°	103	104	105	105	106	106	105	104
160.0°	83	84	84	85	86	86	85	84
165.0°	64	65	66	67	68	67	67	66
170.0°	47	47	49	50	51	51	50	50
175.0°	32	32	34	34	35	36	35	34
180.0°	0	0	0	0	0	0	0	0

Luminous Intensity (cd) Distribution Data (cont.)

C y	180°	202.5°	225°	247.5°	270°	292.5°	315°	337.5°
0.0°	587	587	587	587	587	587	587	587
5.0°	585	585	586	585	587	588	588	589
10.0°	580	581	583	584	585	587	589	590
15.0°	577	578	580	582	585	587	588	591
20.0°	573	574	576	579	584	586	589	590
25.0°	569	570	573	575	580	585	588	591
30.0°	564	565	568	572	578	583	586	589
35.0°	559	559	562	567	573	579	583	585
40.0°	551	552	555	560	567	573	577	580
45.0°	542	544	548	553	560	566	570	573
50.0°	532	533	537	542	549	556	561	564
55.0°	520	521	526	531	538	545	549	552
60.0°	507	508	512	517	525	531	535	538
65.0°	492	493	498	501	509	515	520	522
70.0°	475	477	480	484	492	497	502	504
75.0°	457	458	462	466	473	478	482	485
80.0°	437	439	442	446	452	457	461	464
85.0°	417	418	421	425	430	435	439	441
90.0°	395	397	400	403	409	413	415	417
95.0°	374	375	378	382	385	389	391	392
100.0°	351	352	355	357	361	364	366	368
105.0°	328	329	331	334	337	339	341	343
110.0°	304	305	308	310	312	315	315	317
115.0°	281	282	284	286	288	289	290	291
120.0°	258	258	260	262	263	264	265	266
125.0°	234	235	236	237	239	239	240	240
130.0°	211	212	213	213	214	214	214	215
135.0°	188	189	189	190	190	190	190	190
140.0°	165	166	166	166	167	166	166	167
145.0°	144	144	144	143	144	143	143	144
150.0°	121	121	121	120	120	120	120	120
155.0°	100	100	100	100	99	99	98	99
160.0°	81	81	81	80	79	79	78	79
165.0°	63	63	62	62	61	61	60	60
170.0°	47	47	46	46	45	44	44	44
175.0°	32	32	30	30	28	26	25	26
180.0°	1	1	1	1	0	0	0	0

Zonal Lumen Density Measurement

Deg	Flux (lm)	%	Deg	Flux (lm)	%
0-5	14.0	0.29	0-5	14.0	0.29
5-10	41.9	0.87	0-10	56.0	1.16
10-15	69.4	1.43	0-15	125.4	2.59
15-20	96.2	1.99	0-20	221.6	4.58
20-25	122.0	2.53	0-25	343.6	7.11
25-30	146.5	3.03	0-30	490.1	10.14
30-35	169.4	3.50	0-35	659.4	13.64
35-40	190.2	3.93	0-40	849.6	17.57
40-45	208.7	4.32	0-45	1058.3	21.89
45-50	224.3	4.64	0-50	1282.6	26.53
50-55	236.7	4.89	0-55	1519.3	31.42
55-60	245.9	5.09	0-60	1765.1	36.51
60-65	251.5	5.20	0-65	2016.7	41.71
65-70	253.7	5.25	0-70	2270.4	46.96
70-75	252.5	5.22	0-75	2522.9	52.18
75-80	248.1	5.13	0-80	2771.0	57.31
80-85	240.6	4.98	0-85	3011.6	62.29
85-90	230.4	4.77	0-90	3242.0	67.06
90-95	217.9	4.51	0-95	3459.9	71.57
95-100	203.4	4.20	0-100	3663.4	75.77
100-105	187.5	3.88	0-105	3850.8	79.65
105-110	170.3	3.52	0-110	4021.2	83.17
110-115	152.5	3.16	0-115	4173.7	86.33
115-120	134.5	2.78	0-120	4308.2	89.11
120-125	116.5	2.41	0-125	4424.6	91.52
125-130	99.0	2.05	0-130	4523.6	93.57
130-135	82.3	1.70	0-135	4605.9	95.27
135-140	66.7	1.38	0-140	4672.6	96.65
140-145	52.4	1.08	0-145	4725.0	97.73
145-150	39.6	0.82	0-150	4764.6	98.55
150-155	28.5	0.59	0-155	4793.2	99.14
155-160	19.4	0.40	0-160	4812.5	99.54
160-165	12.1	0.25	0-165	4824.6	99.79
165-170	6.7	0.14	0-170	4831.3	99.93
170-175	2.9	0.06	0-175	4834.2	99.99
175-180	0.5	0.01	0-180	4834.6	100.00

## 6. Product Photo



## Directions

1. The information marked "superscript #" is provided by the applicant, the laboratory is not responsible for its authenticity and this information can affect the validity of the result in the test report.
2. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.
3. Otherwise required by the applicant or Product Regulations, Decision Rule in this report did not consider the uncertainty.
4. The extended uncertainty given in this report is obtained by combining the standard uncertainty times the coverage factor K with the 95% confidence interval.
5. This report cannot be reproduced except in full, without prior written approval of the Company.
6. This report is valid only with a valid digital signature. The digital signature may be available only under the Adobe software above version 7.0.

\*\*\*\*\*END OF REPORT\*\*\*\*\*