




DIRECT PL

MODEL

Model: 5.5PLH/xxx/DIR/RC
 8.5PLH/xxx/DIR/R
 10.5PLH/xxx/DIR
 14.5PLH/xxx/DIR
 6PLV/xxx/DIR/R
 9.5PLV/xxx/DIR/R
 9.5PLV/xxx/DIR/RC
 11PLV/xxx/DIR/R
 17PLV/xxx/DIR

Where xxx means 824-965 which indicates CIR and color temperature



EMERGENCY BALLAST COMPATIBILITY

Model: 5.5PLH/xxx /DIR/RC 6PLV/xxx/DIR/R

Brand	Model	Compatibility
Bodine	B30ST	Not Compatible
	LP600	Compatible
Iota	I-320	Compatible
Lithonia	PS1400QD	Compatible
Fulham	FH5-DUAL-1400L	Compatible
Philips	ICF-2S13-H1-LD	Compatible

EMERGENCY BALLAST COMPATIBILITY

Model: 8.5PLH/xxx/DIR/R

Brand	Model	Compatibility
Bodine	B30ST	Not Compatible
	LP600	Compatible
Iota	I-320	Compatible
Lithonia	PS1400QD	Compatible
Fulham	FH5-DUAL-1400L	Compatible



DIRECT PL

EMERGENCY BALLAST COMPATIBILITY

Model: 10.5PLH/xxx/DIR

Brand	Model	Compatibility
Bodine	B30ST	Compatible
	LP600	Compatible
lota	I-320	Compatible
	I-26-EM-A	Compatible
	ISD-420-EM-B	Compatible
Lithonia	PS1400QD	Compatible
Fulham	FH5-DUAL-1400L	Compatible

EMERGENCY BALLAST COMPATIBILITY

Model: 14.5PLH/xxx/DIR 9.5PLV/xxx/DIR/R 9.5PLV/xxx/DIR/RC 11PLV/xxx/DIR/R

Brand	Model	Compatibility
Bodine	B30ST	Not Compatible
	LP600	Compatible
lota	I-320	Compatible
Lithonia	PS1400QD	Compatible
Fulham	FH5-DUAL-1400L	Compatible

EMERGENCY BALLAST COMPATIBILITY

Model: 17PLV/xxx/DIR

Brand	Model	Compatibility
Bodine	B30ST	Compatible
	LP600	Compatible
lota	I-320	Compatible
Lithonia	PS1400QD	Compatible
Fulham	FH5-DUAL-1400L	Compatible

GREEN CREATIVE has provided this emergency ballast compatibility chart for guidance when selecting an emergency ballast and lamp combination. Lamps were tested for compatibility with the above listed emergency ballasts. Emergency ballasts that do not appear on the chart might still be compatible but have not been tested. All testing has been performed with a stable main supply. The quality of the local main, existing installation and wiring, as well as different manufacturer versions of the above emergency ballasts may affect lamp performance. Since no assurance can be provided regarding these factors, it is a general recommendation to perform a test on-site prior to installing the LED lamps.