



LM-79-08 Test Report

for

GREEN CREATIVE LTD

756 North Zhongshan Rd., Unit B301 Zhabei District, Shanghai

LED LAMP

Model: 13PAR30DIM/930NF25

Laboratory: Leading Testing Laboratories

NVLAP CODE: 200960-0

3rd Floor, Bld. 2, NO. 96 Longchuanwu Rd Qianjiang Economy Dev. Zone, Yuhang Dist,
Hangzhou, Zhejiang Province, China 311100

Tel: +86 571 86376106

www.ledtestlab.com

Report No.: HZ17020041i

The laboratory that conducted the testing detailed in this report has been accredited for SSL by NVLAP.

Review by:

April Zou

Engineer: April Zou
Mar. 07, 2017

Approved by:



Jim Zhang

Manager: Jim Zhang
Mar. 07, 2017

Note: This report does not imply product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government.

Test Summary

Sample Tested: 13PAR30DIM/930NF25

Luminous Efficacy (Lumens /Watt)	Total Luminous Flux (Lumens)	Power (Watts)	Power Factor
83.4	1067.0	12.80	0.9486
CCT (K)	CRI	Stabilization Time (Light & Power)	
3017	92.3	60	

Table 1: Executive Data Summary

Note: The above results are recorded/ derived from measurements made using an Integrating Sphere.

Test specifications:

Date of Receipt : Feb. 27, 2017

Date of Test : Mar. 01, 2017

Test item : Total Luminous Flux, Luminous Distribution Intensity, Luminous Efficacy, Correlated Color Temperature, Color Rendering Index, Chromaticity Coordinate, Electrical parameters

Reference Standard : IESNA LM-79-2008 Approved Method for the Electrical and Photometric Measurements of Solid-State Lighting Products

TABLE OF CONTENT

LM-79-08 Test Report.....	1
Test Summary.....	2
Sample Photos.....	4
TEST RESULTS	5
Goniophotometer Method	6
Spectral Power Distribution - Sphere Spectroradiometer Method	7
Chromaticity Diagram - Sphere Spectroradiometer Method.....	8
Nominal CCT Quadrangles – Sphere Spectroradiometer Method	9
Zonal Lumen Tabulation- Goniophotometer Method	10
Luminous Intensity Distribution Plots- Goniophotometer Method.....	12
Luminous Intensity Data- Goniophotometer Method.....	13
EQUIPMENT LIST	14
TEST METHODS	14
Seasoning of SSL Product.....	14
Sphere-Spectroradiometer Method- Photometric and Electrical Measurements.....	14
Goniophotometer Method	15
Photometric and Electrical Measurements.....	15
Color Characteristics Measurements.....	15
Color Spatial Uniformity	15

Sample Photos



Figure 1- Overview of the sample

Equipment Under Test (EUT)

Name	: LED LAMP
Model	: 13PAR30DIM/930NF25
Electrical Ratings	: 120Vac, 60Hz, 13W
Product Description	: E26 base, 3000K
Manufacturer	: GREEN CREATIVE LTD
Address	: 756 North Zhongshan Rd., Unit B301 Zhabei District, Shanghai

TEST RESULTS

Test ambient temperature was 25.0°C.

Base orientation was Base up. Test was conducted without a dimmer in the circuit.

The stabilization time of the sample was 60 minutes, and the total operating time including stabilization was 70 minutes.

Sphere-Spectroradiometer Method

Parameter	Result
Test Voltage (V)	120.0
Voltage frequency (Hz)	60
Test Current (A)	0.112
Power Factor	0.9486
Test Power (W)	12.81
THD A%	27.72
Luminous Efficacy (lm/W)	83.4
Total Luminous Flux (lm)	1067.0
Color Rendering Index (CRI)	92.3
R9	63.3
Correlated Color Temperature (CCT)(K)	3017
Chromaticity Chroma x	0.4353
Chromaticity Chroma y	0.4031
Chromaticity Chroma u	0.2500
Chromaticity Chroma v	0.3472
Duv	0.0003
Chromaticity Chroma u'	0.2500
Chromaticity Chroma v'	0.5208

Special Color Rendering Indices	
R1	92.6
R2	95.1
R3	95.6
R4	92.4
R5	91.7
R6	93.1
R7	93.5
R8	84.3
R9	63.3
R10	86.9
R11	92.2
R12	77.8
R13	93.2
R14	96.8
Rf	90
Rg	100

Table 2: Test data per Sphere-Spectroradiometer Method

Note: According to CIE 1976 (u',v') diagram, $u' = u = 4x/(-2x+12y+3)$, $v' = 3v/2 = 9y/(-2x+12y+3)$.

Goniophotometer Method

Test ambient temperature was 24.7°C.

The photometric distance is 2.47m.

Luminous data was taken at 0.5°vertical intervals and 10°horizontal intervals.

Parameter	Result
Test Voltage (V)	120.0
Voltage frequency (Hz)	60
Test Current (A)	0.113
Power Factor	0.9480
Test Power (W)	12.91
Luminous Efficacy (lm/W)	84.0
Total Luminous Flux (lm)	1084.3
Beam Angle (°)	20.0
Center Beam Candle Power (cd)	4883
Spacing Criteria	0.35(0°-180°)/ 0.32(90°-270°)
Zonal Lumens in the 0°-60°Zone	95.74%
Zonal Lumens in the 60°-90°Zone	4.16%
Zonal Lumens in the 90°-120°Zone	0.00%
Zonal Lumens in the 120°-180°Zone	0.09%

Table 3: Test data per Goniophotometer Method

Spectral Power Distribution - Sphere Spectroradiometer Method





Chart 1: Spectral Power Distribution

Spectral Distribution over Visible Wavelength							
WL(nm)	Radiant(Watts)	WL(nm)	Radiant(Watts)	WL(nm)	Radiant(Watts)	WL(nm)	Radiant(Watts)
380	1.78E-04	485	4.86E-03	590	1.80E-02	695	8.50E-03
385	1.47E-04	490	5.42E-03	595	1.87E-02	700	7.57E-03
390	1.74E-04	495	6.24E-03	600	1.93E-02	705	6.66E-03
395	1.77E-04	500	7.22E-03	605	1.98E-02	710	5.87E-03
400	1.96E-04	505	8.23E-03	610	2.04E-02	715	5.18E-03
405	2.33E-04	510	9.17E-03	615	2.07E-02	720	4.55E-03
410	3.25E-04	515	1.01E-02	620	2.09E-02	725	3.97E-03
415	4.99E-04	520	1.08E-02	625	2.10E-02	730	3.45E-03
420	7.49E-04	525	1.15E-02	630	2.09E-02	735	2.98E-03
425	1.19E-03	530	1.21E-02	635	2.05E-02	740	2.57E-03
430	1.82E-03	535	1.26E-02	640	2.01E-02	745	2.21E-03
435	2.85E-03	540	1.31E-02	645	1.93E-02	750	1.91E-03
440	4.51E-03	545	1.37E-02	650	1.85E-02	755	1.65E-03
445	7.32E-03	550	1.40E-02	655	1.75E-02	760	1.43E-03
450	1.07E-02	555	1.45E-02	660	1.64E-02	765	1.23E-03
455	1.06E-02	560	1.49E-02	665	1.53E-02	770	1.06E-03
460	8.23E-03	565	1.54E-02	670	1.41E-02	775	9.06E-04
465	6.85E-03	570	1.58E-02	675	1.29E-02	780	7.72E-04
470	5.90E-03	575	1.64E-02	680	1.18E-02		
475	4.86E-03	580	1.69E-02	685	1.06E-02		
480	4.59E-03	585	1.74E-02	690	9.55E-03		

Table 4: Spectral Power Distribution Numerical Data per Sphere - Spectroradiometer Method

Chromaticity Diagram - Sphere Spectroradiometer Method



Tristimulus values(x, y): (0.4353, 0.4031)

Chart 2: Chromaticity Diagram per Sphere - Spectroradiometer Method

Note: The location on the diagram of the tristimulus coordinates are indicated by the blue diamond.

Nominal CCT Quadrangles – Sphere Spectroradiometer Method




Chart 3: Plot of Lamp x/y coordinates on CIE 1931 Chromaticity Diagram

Zonal Lumen Tabulation- Goniophotometer Method

$\gamma(^{\circ})$	Lumens	% Total
0- 10	338.182	31.19%
10- 20	360.886	33.28%
20- 30	152.842	14.10%
30- 40	79.391	7.32%
40- 50	64.655	5.96%
50- 60	42.125	3.89%
60- 70	26.187	2.42%
70- 80	14.742	1.36%
80- 90	4.229	0.39%
90-100	0.018	0.00%
100-110	0.006	0.00%
110-120	0.016	0.00%
120-130	0.035	0.00%
130-140	0.106	0.01%
140-150	0.247	0.02%
150-160	0.314	0.03%
160-170	0.217	0.02%
170-180	0.062	0.01%
Total	1084.3	100%

$\gamma(^{\circ})$	Lumens	% Total
0- 60	1038.081	95.74%
60- 90	45.158	4.16%
0-90	1083.239	99.91%
90- 180	1.021	0.09%
0- 180	1084.3	100%

Table 5: Zonal Lumen Data




Chart 4: Illuminance Plot (Footcandles)

Luminous Intensity Distribution Plots- Goniophotometer Method




Chart 5: Isocandela Plot




Chart 6: Polar Candela Distribution

Luminous Intensity Data- Goniophotometer Method

Table--1 UNIT: cd

C (DEG) y (DEG)	0	22.5	45	67.5	90	112.5	135	157.5	180	202.5	225	247.5	270	292.5	315	337.5			
0	4883	4883	4883	4883	4883	4883	4883	4883	4883	4883	4883	4883	4883	4883	4883	4883			
5	4078	4098	4131	4199	4283	4332	4352	4319	4256	4190	4144	4107	4064	4010	4001	4035			
10	2361	2425	2494	2618	2711	2712	2697	2659	2550	2432	2345	2269	2187	2113	2143	2248			
15	1195	1244	1296	1376	1441	1431	1435	1447	1398	1321	1265	1225	1156	1079	1077	1126			
20	572	592	633	713	760	751	765	787	752	686	642	624	592	540	525	544			
25	272	271	287	336	363	349	361	383	358	312	295	299	288	258	250	265			
30	157	157	162	181	192	184	189	198	188	172	166	166	163	156	155	157			
35	118	117	118	125	130	124	126	127	127	125	119	118	118	122	129	123			
40	99.7	102	103	105	109	101	99.5	99.0	103	106	98.9	96.4	100	108	114	107			
45	82.3	83.9	85.6	88.2	91.7	85.5	81.5	81.2	83.0	84.8	79.9	77.8	82.1	86.4	87.4	86.5			
50	62.7	65.5	67.5	67.3	69.1	67.8	64.1	64.6	62.8	62.6	60.9	59.4	61.2	61.9	63.5	63.9			
55	44.8	45.9	46.8	47.9	49.9	48.4	47.1	47.7	46.8	45.8	44.3	44.0	44.7	44.3	44.8	45.4			
60	33.3	33.9	34.3	35.2	36.3	35.5	35.4	35.5	35.1	34.2	33.3	33.2	33.5	33.0	33.1	33.4			
65	25.4	26.0	26.2	26.9	27.7	27.3	27.5	27.4	26.9	26.2	25.4	25.4	25.6	25.3	25.2	25.3			
70	19.0	19.5	19.8	20.4	20.9	20.8	21.0	20.9	20.3	19.7	19.1	19.0	19.1	18.7	18.8	18.8			
75	13.2	13.7	13.9	14.5	15.0	15.0	15.1	15.0	14.5	14.0	13.4	13.2	13.1	12.9	12.9	13.0			
80	7.82	8.25	8.51	9.14	9.44	9.67	9.69	9.60	9.12	8.68	8.19	7.85	7.66	7.51	7.55	7.57			
85	3.12	3.40	3.69	4.14	4.41	4.64	4.63	4.56	4.17	3.78	3.39	3.14	2.96	2.85	2.86	2.92			
90	0.08	0.05	0.15	0.39	0.53	0.68	0.63	0.58	0.35	0.17	0.04	0.02	0.05	0.06	0.09	0.09			
95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			
100	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01			
105	0.01	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.01	0.01			
110	0.01	0.01	0.01	0.01	0.00	0.01	0.01	0.01	0.00	0.00	0.01	0.01	0.01	0.01	0.01	0.02			
115	0.02	0.02	0.02	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.02	0.02	0.02	0.02	0.02			
120	0.03	0.03	0.03	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.03	0.03	0.03	0.03	0.03			
125	0.05	0.04	0.04	0.03	0.02	0.02	0.03	0.02	0.02	0.03	0.03	0.05	0.05	0.05	0.05	0.05			
130	0.09	0.08	0.07	0.04	0.04	0.04	0.04	0.04	0.04	0.05	0.05	0.10	0.10	0.10	0.10	0.10			
135	0.19	0.17	0.16	0.08	0.08	0.08	0.08	0.08	0.08	0.09	0.09	0.18	0.19	0.20	0.20	0.19			
140	0.33	0.33	0.30	0.14	0.14	0.14	0.14	0.14	0.15	0.16	0.16	0.32	0.34	0.35	0.35	0.35			
145	0.55	0.55	0.51	0.25	0.24	0.24	0.25	0.25	0.25	0.25	0.25	0.52	0.56	0.57	0.57	0.56			
150	0.80	0.80	0.74	0.34	0.33	0.33	0.34	0.34	0.34	0.35	0.34	0.75	0.80	0.81	0.81	0.81			
155	1.00	1.02	0.92	0.40	0.40	0.40	0.41	0.41	0.42	0.42	0.40	0.92	1.00	1.01	1.01	1.00			
160	1.11	1.14	1.01	0.43	0.43	0.43	0.44	0.44	0.45	0.45	0.40	1.00	1.11	1.12	1.12	1.12			
165	1.13	1.17	0.99	0.44	0.45	0.45	0.46	0.46	0.47	0.47	0.43	0.97	1.11	1.12	1.13	1.13			
170	1.04	1.08	0.87	0.47	0.48	0.48	0.49	0.49	0.49	0.48	0.45	0.79	0.98	1.00	1.01	1.03			
175	0.84	0.83	0.61	0.47	0.47	0.48	0.48	0.48	0.48	0.49	0.49	0.48	0.74	0.77	0.79	0.81			
180	0.52	0.52	0.52	0.52	0.52	0.52	0.52	0.52	0.52	0.52	0.52	0.52	0.52	0.52	0.52	0.52			

Table 6: Luminous Intensity Data

EQUIPMENT LIST

Test Equipment	Model	Equipment No.	Calibration Date	Calibration Due date
Goniophotometer system	GO-R5000	HZTE011-01	Jul. 27, 2016	Jul. 26, 2017
Digital Power Meter	PF2010A	HZTE028-01	Jul. 27, 2016	Jul. 26, 2017
AC Power Supply	PCR 500L	HZTE001-08	Jul. 27, 2016	Jul. 26, 2017
DC Power Supply	WY12010	HZTE004-03	Jul. 27, 2016	Jul. 26, 2017
Temperature Meter	TES1310	HZTE017-01	Jul. 27, 2016	Jul. 26, 2017
Standard source	D908	HZTE012-01	Jul. 27, 2016	Jul. 26, 2017
Integrate Sphere system	2M	HZTE015-01	Jul. 27, 2016	Jul. 26, 2017
Digital Power Meter	WT210	HZTE008-01	Jul. 27, 2016	Jul. 26, 2017
AC Power Supply	PCR 500L	HZTE001-07	Jul. 27, 2016	Jul. 26, 2017
DC Power Supply	6154	HZTE004-04	Jul. 27, 2016	Jul. 26, 2017
Temperature and humidity recorder	JR900	HZTE018-01	Jul. 27, 2016	Jul. 26, 2017
Standard source	SCL-1400	HZTE012-02	Jul. 27, 2016	Jul. 26, 2017

Table 8: Test Equipment List

TEST METHODS

Seasoning of SSL Product

For the purpose of rating new SSL products, SSL products shall be tested with no seasoning. Therefore, no seasoning was performed.

Sphere-Spectroradiometer Method- Photometric and Electrical Measurements

A Labsphere Model CDS 2100 Spectroradiometer and Two Meter Sphere was used to measure correlated color temperature, chromaticity coordinates, and the color rendering index for each SSL unit. The coating reflectance of each sphere is 98%. The measure geometry is 4π . Self-absorption correction is conducted in testing. Bandwidth of spectroradiometer is 350nm-1050nm.

Ambient temperature was measured at a position inside the sphere. Each SSL unit was operated on the client provided driver at the rated input voltage in its designated orientation.

The stabilization time typically ranges from 30 min (small integrated FA19 Lamps) to 2 or more hours for large SSL luminaires). It can be judged that stability is reached when the variation (maximum – minimum) of at least 3 readings of the light output and electrical power over a period of 30 min, taken 15 minutes apart, is less than 0.5 %.

Electrical measurements including voltage, current, and power were measured using the Yokogawa Power Analyzer.

The standard reference of the integrated sphere system is halogen incandescent lamp, the intensity distribution type is omni-directional, and is traceable to the National Institute of Standards and Technology.

The uncertainty of integrating sphere system reported in this document is expended uncertainty is 1.06% with a coverage factor $k=2$.

Goniophotometer Method

Photometric and Electrical Measurements

An EVERFINE Type C Model GO-R5000 Goniophotometer was used to measure the intensity at each angle of distribution for each sample. The photometric distance is 2.475m for near-field measurement or 30m for far-field measurement. Bandwidth of spectroradiometer is 380nm-780nm.

Ambient temperature was measured at the same height of the sample mounted on the Goniophotometer equipment. Each SSL unit was operated on the client provided driver at the rated input voltage in its designated orientation.

The stabilization time typically ranges from 30 min (small integrated FA19 Lamps) to 2 or more hours for large SSL luminaires). It can be judged that stability is reached when the variation (maximum – minimum) of at least 3 readings of the light output and electrical power over a period of 30 min, taken 15 minutes apart, is less than 0.5 %.

Electrical measurements including voltage, current, and power were measured using the Everfine Digital Power Meter.

Some graphics were created with Photometric Plus software.

The standard reference of the Goniophotometer system is halogen incandescent lamp, the intensity distribution type is omni-directional, and is traceable to the National Institute of Metrology P.R. China.

The uncertainty of goniophotometer system reported in this document is expanded uncertainty is 1.94% with a coverage factor $k=2$.

Color Characteristics Measurements

The color characteristics of SSL products include chromaticity coordinates, correlated color temperature, and color rendering index. These characteristics of SSL products may be spatially non-uniform, and thus, in order that they can be specified accurately, the color quantities shall be measured as values that are spatially average, weighted to intensity, over the angular range where light is intentionally emitted from the SSL product. The color characteristics measurements are using gonio-spectroradiometer.

Color Spatial Uniformity

The characteristics of SSL products may be spatially non-uniform, the chromaticity coordinate shall be measured at two vertical planes ($C=0^\circ/180^\circ$ and $C=90^\circ/270^\circ$) and at 10° or less intervals for vertical angle until the light output dropped to below 10% of the peak intensity. The averaged weighted chromaticity coordinate was calculated from these points. The data was then analyzed to check for delta color differences of the u' , v' chromaticity coordinates. The spatial non-uniformity of chromaticity, $\Delta u'v'$, is determined as the maximum

deviation (distance on the CIE (u' , v') diagram) among all measured points from the spatially averaged chromaticity coordinate.

The geometry for the chromaticity measurement using gonio-spectroradiometer is shown as following.



*** End of Report ***

This report is considered invalidated without the Special Seal for Inspection of the LTL. This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of LTL, this test report shall not be copied except in full and published as advertisement.